

**476.62 Energy-efficient lighting required.**

All public utility-owned exterior flood lighting, including but not limited to street and security lighting, shall be replaced when worn-out exclusively with high pressure sodium lighting or lighting with equivalent or better energy efficiency as approved in rules adopted by the board.

[89 Acts, ch 297, §12](#)

Referred to in [§474.5](#), [§476.1A](#), [§476.1B](#)